



**CITY OF SAN MARCOS  
STANDARD PRODUCTS LIST**

SPL No. WW-27G

Sheet 1 of 1

for

**JOINT RESTRAINT GASKETS FOR DUCTILE IRON PIPE (4 inch to 16 inch)**

**ISSUED: 09/01/2014**

**REVISED: 02/01/2022**

**DESCRIPTION:** Gaskets, rubber with stainless steel teeth for wedging action, used to provide restrained joints on standard push-on (socket and spigot) pipe 4-inch through 16-inch diameter. Gaskets shall meet performance requirements of AWWA C111.

<b>APPROVAL DATE</b>	<b>MANUFACTURER</b>	<b>PRODUCT IDENTIFICATION/COMMENT</b>
1/1/2007	AMERICAN CAST IRON PIPE P.O. Box 2727 Birmingham, AL 35202	Fast-Grip Gasket used with Fastite Pipe. See notes.
1/1/2007	U.S. PIPE & FOUNDRY CO. P.O. Box 10406 Birmingham, AL 35202	Field Lok 350 Gasket used with Tyton Joint Pipe. See notes.
7/1/2011	McWANE, INC. 1201 Vanderbilt Road Birmingham, AL 35234	Sure Stop 350 Gasket used with Tyton Joint Pipe. See notes.
4/1/2013	ROMAC INDUSTRIES, INC. 21919 20th Avenue SE Suite 100 Bothell, WA 98021	Piranha Gasket used with Tyton Joint Pipe. See notes.
2/1/2022	Electrosteel USA 1101 Louisville Rd. Savannah, GA 31415	Field Lok 350, Sure Stop 350 and/or Barracuda. See notes.

**NOTE:**

1. These gaskets shall be used only on pipe joints, not fittings.
2. Fittings, used on pipe that is restrained with these gaskets, shall be MJ that are restrained using devices listed on SPL WW-27A.
3. Warning tape shall be placed per SPL WW-597A.
4. Not to be used on pipe larger than 16 inches unless approved by City of San Marcos Public Services Water Dept.
5. Not to be used on pipe installed in encasement pipe unless approved by manufacturer.
6. Not to be used on pipe installed above ground.

[Inspector—show location of restrained pipe and fittings on intersection drawings. Also show on as-constructed drawings along with manufacturer's name.]