



**CITY OF SAN MARCOS
STANDARD PRODUCTS LIST**

SPL No. WW-123

Sheet 1 of 1

for

SWING CHECK VALVES, AWWA C508

ISSUED: 09/01/2014

REVISED: 09/27/2017

DESCRIPTION: Valves, swing check with outside lever and weight complying with current AWWA C508. Iron Body, bronze mounted for water works service. Copper alloy parts (bronze and brass) shall not contain over 16 percent zinc. Copper alloy UNS No. shall be shown on permanent external marking in addition to markings required by AWWA C508. Valves shall be “lead free” and marked by stamping, etching, or casting “NL” in the main body or by other methods acceptable to City.

APPROVAL DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT
12/31/1985	M & H VALVE COMPANY P.O. Box 2088 Anniston, AL 36202	M & H Style 159-02
8/6/1974	MUELLER COMPANY 500 W. Eldorado St. Decatur, IL 67525	A-2600-6-01
2/24/1987	AMERICAN FLOW CONTROL P.O. Box 3077 Vernon, CT 06066	52 – SC
9/27/2017	APCO VALVE & PRIMER CORP. 1230 So. Wright Blvd. Schaumburg, IL 60193	APCO Series 250 APCO Series 6000 CLW
7/1/1994	CLOW CORPORATION/VALVE DIVISION P.O. Box 350 Oskaloosa, IA 52577	Style 1106LW

NOTE: