



**CITY OF SAN MARCOS  
STANDARD PRODUCTS LIST**

SPL No. WW-144

Sheet 1 of 1

**for  
Water Meters**

**ISSUED: 09/29/2014**

**REVISED: 08/17/2018**

**DESCRIPTION:** 1. Accepted Metering Devices

APPROVAL DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT
9/8/2015	Sensus 8601 Six Forks Road, Suite 700 Raleigh, NC 27615	<p><b>IRRIGATION METERS</b> No by-pass required</p> <ul style="list-style-type: none"> <li>· 5/8", 3/4" &amp; 1" – SR II</li> <li>· 1 1/2" or larger – Omni T Turbo meter</li> </ul> <p><b>COMMERCIAL DOMESTIC METERS</b> By-pass required on all 1 1/2" or larger services</p> <ul style="list-style-type: none"> <li>· 1 1/2" or larger service - Omni "C" meter</li> <li>· 5/8", 3/4" &amp; 1" - SR II</li> </ul> <p><b>UTILITY LINE/COMBO METERS</b> By-pass required</p> <ul style="list-style-type: none"> <li>· 6" or larger only - OMNI Fireline (F<sup>2</sup>)</li> </ul> <p><b>RESIDENTIAL DOMESTIC METERS</b></p> <ul style="list-style-type: none"> <li>· 5/8" x 3/4" through 1" - SR II</li> </ul> <p><b>AUTOMATIC FLUSH VALVE</b></p> <ul style="list-style-type: none"> <li>· 2" - Omni T Turbo meter</li> </ul>

**NOTE:**

1. All meters shall be U.S. gallons measurement
2. All meters shall be installed with ITRON-in-line connector (IOC) and programmed to read all 8 dials.
3. All meters shall be installed with an integrated strainer