



**CITY OF SAN MARCOS
STANDARD PRODUCTS LIST**

SPL No. WW-144

Sheet 1 of 1

**for
Water Meters**

ISSUED: 09/29/2014

REVISED: 01/01/2022

DESCRIPTION: 1. Accepted Metering Devices

APPROVAL DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT
9/8/2015	Sensus 8601 Six Forks Road, Suite 700 Raleigh, NC 27615	<p>IRRIGATION METERS No by-pass required</p> <ul style="list-style-type: none"> · 5/8", 3/4" & 1" – SR II · 1 1/2" or larger – Omni T Turbo meter <p>COMMERCIAL DOMESTIC METERS By-pass required on all 1 1/2" or larger services</p> <ul style="list-style-type: none"> · 1 1/2" or larger service - Omni "C" meter · 5/8", 3/4" & 1" - SR II <p>UTILITY LINE/COMBO METERS By-pass required</p> <ul style="list-style-type: none"> · 6" or larger only - OMNI Fireline (F²) <p>RESIDENTIAL DOMESTIC METERS</p> <ul style="list-style-type: none"> · 5/8" x 3/4" through 1" - SR II <p>AUTOMATIC FLUSH VALVE</p> <ul style="list-style-type: none"> · 2" - Omni T Turbo meter

NOTE:

1. All meters shall be U.S. gallons measurement
2. All meters shall be installed with ITRON-in- line connector (IOC) and programmed to read all 8 dials.
3. All meters shall be installed with an integrated strainer
- 4 All reclaimed meters shall have purple housing