



**CITY OF SAN MARCOS
STANDARD PRODUCTS LIST**

SPL No. WW-227B

Sheet 1 of 1

for

PVC WASTEWATER LINE FITTINGS

ISSUED: 09/01/2014

REVISED: 02/10/2020

DESCRIPTION: Fittings, polyvinyl chloride (PVC) gravity sewer, meeting ASTM D3034 with minimum stiffness of 115 psi or meeting ASTM F679 with minimum stiffness of 75 psi and with elastomeric gasket joints meeting ASTM F1336 and gaskets meeting ASTM F477. (10" fittings for maintenance only.)

APPROVAL DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT
7/1/1996	TIGRE USA, INC. (Formerly Vassallo) 2315 Beloit Avenue Janesville, WI 53546	ASTM D3034 or F679 Includes D3034 6" two-way cleanout fitting See notes below
1/4/1999	THE HARRINGTON CORP. P.O. Box 10335 Lynchburgh, VA 24506	Marked "HARCO" (fittings are gray) ASTM D3034 Includes Part No. 313-0806 for wastewater services connecting to AWWA C900 DR 14 PVC wastewater mains. See SPL WW-227D. (fitting is white) See notes below
2/10/2020	NAPCO 2801 Post Oak Blvd, Suite 600 Houston, Texas 77056 (AKA: Royal Building Products OR Plastic Trends, Inc)	ASTM D3034 See notes below Includes 6" two-way cleanout fitting
10/1/1998	GPK PRODUCTS, INC. 1601 43rd Ave. Fargo, ND 58102	ASTM D3034 or F679 See notes below
1/4/1999	MULTI-FITTINGS CORPORATION 4507 LeSaint Ct. Fairfield, OH 45014	ASTM D3034 with Multi-Loc gaskets, Includes 6" two-way cleanout fitting. See notes below
1/2/1998	SPECIFIED FITTINGS, INC. P.O. Box 28157 Bellingham, WA 98226	ASTM D3034 or F679 12" larger body size only. See notes below

NOTE:

1. Acceptable fitting sizes are 6" minimum (service laterals only), 8", 12", 15", 18", 21", and 24".
2. All joint gaskets shall be secured in place.