



**CITY OF SAN MARCOS
STANDARD PRODUCTS LIST**

SPL No. WW-276

Sheet 1 of 1

for

BALL VALVES FOR PROPERTY OWNER'S CUT OFF

ISSUED: 09/01/2014

REVISED: __/__/__

DESCRIPTION: Valves, Ball, with stainless steel handles, used on meter nipple for property owner's cut off. Conforms to specification MSS-SP-110. Threaded ends comply with ANSI B2.1CSA/AGA/CGA certified. All valves shall be full port with chrome-plated bronze ball. Valves shall be "lead free" and marked by stamping, etching, or casting "NL" in the main body or by other methods acceptable to City.

APPROVAL DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT
7/1/2002	MIDLAND METAL MFG 2021 Forest Ave. Kansas City, MO 64108	IPS ball valves, full port, 600 WOG with stainless steel tee (wing style) handle and nut ¾" – 948-154ST 1" – 948-155ST
7/1/2002	NIBCO P.O. Box 1167 Elkhart, IN 46515-1167	IPS ball valves, full port, SWP 600 CWP with stainless steel lever handle and nut (use only in rectangular or square valve box providing clearance for handle) ¾" – T-585-70-SSHN 1" – T-585-70-SSHN 1½" – T-585-70-SSHN 2" – T-585-70-SSHN
7/1/2004	MATCO-NORCA P.O. Box 27 Route 22 Brewster, NY 10509	IPS ball valves, full port, 600 WOG with stainless steel tee (wing style) handle, nut and washer ¾" – 759T04TS 1" – 759T05TS
7/1/2004	WEBSTONE CO., INC. P.O. Box 59 Worcester, MA 01613	IPS ball valves, full port, 600 WOG with stainless steel tee (wing style) handle, nut and washer ¾" – 41703SSW 1" – 41704SSW 1½" – 41706SSW 2" – 41707SSW
7/1/2005	B & K (MUELLER) INDUSTRIES, INC. 2600 Elmhurst Road Elk Grove, IL 60007	¾" and 1" IPS ball valves, full port, 600 WOG with stainless steel tee (wing style) handle ¾" – 107-824TNL 1" – 107-825TNL

NOTE: