



**CITY OF SAN MARCOS
STANDARD PRODUCTS LIST**

SPL No. WW-308

Sheet 1 of 1

for

PVC WATER PIPE (4-INCH TO 12-INCH DIAMETER)

ISSUED: 09/01/2014

REVISED: 01/17/2023

DESCRIPTION: Pipe, polyvinyl chloride (PVC), 4" through 12" cast iron pipe size O.D. with elastomeric gasket joints for water service. AWWA C-900 current, PR 305 psi (DR14).

| APPROVAL DATE | MANUFACTURER | PRODUCT IDENTIFICATION/COMMENT |
|----------------------|--|---|
| 11/30/1984 | JM EAGLE (formerly J-M Pipe & PW Eagle) 9 Peach Tree Hill Road Livingston, NJ 07039 | See notes below |
| 4/1/1993 | WESTLAKE PIPE & FITTINGS (Formerly NAPCO and CERTAINTEED CORP.) 2801 Post Oak Blvd. Suite 600 Houston, TX 77056 | See notes below Includes Certa-Lok restrained joint pipe |
| 4/2/1990 | DIAMOND PLASTICS CORPORATION P.O. Box 2748 Lubbock, TX 79408-2748 | See notes below |
| 10/1/2005 | VINYLTECH CORPORATION 201 South 61st Avenue Phoenix, AZ 85043 | See notes below |
| 10/1/2007 | NORTHERN PIPE PRODUCTS 1309 39th Street NW Fargo, ND 58102 | See notes below |
| 4/1/2012 | PELIFE JET STREAM, INC. P.O. Box 190 Siloam Springs, AR 72761 | See notes below |

NOTE:

1. Material must comply with requirement of description above and be rated above design pressure. Acceptable sizes are 4", 6", 8" and 12".
2. AWWA C900 water pipe for portable water shall be blue in color not be used for anything but potable water.
3. AWWA C900 water pipe for force mains shall be green in color.
4. AWWA C900 water pipe for reclaimed water shall be purple in color.