



**CITY OF SAN MARCOS  
STANDARD PRODUCTS LIST**

SPL No. WW-308

Sheet 1 of 1

**for**

**PVC WATER PIPE (4-INCH TO 12-INCH DIAMETER)**

**ISSUED: 09/01/2014**

**REVISED: 04/29/2019**

**DESCRIPTION:** Pipe, polyvinyl chloride (PVC), 4" through 12" cast iron pipe size O.D. with elastomeric gasket joints for water service. AWWA C-900 current, PR 305 psi (DR14).

<b>APPROVAL DATE</b>	<b>MANUFACTURER</b>	<b>PRODUCT IDENTIFICATION/COMMENT</b>
11/30/1984	JM EAGLE (formerly J-M Pipe & PW Eagle) 9 Peach Tree Hill Road Livingston, NJ 07039	See notes below
10/1/1996	CERTAINTED CORPORATION P.O. Box 860 Valley Forge, PA 19482	See notes below Includes Certa-Lok restrained joint pipe
4/1/1993	NAPCO (FORMERLY NORTH AMERICAN PIPE CORP.) 2801 Post Oak Boulevard Suite 410 Houston, TX 77056	See notes below
4/2/1990	DIAMOND PLASTICS CORPORATION P.O. Box 2748 Lubbock, TX 79408-2748	See notes below
10/1/2005	VINYLTECH CORPORATION 201 South 61st Avenue Phoenix, AZ 85043	See notes below
10/1/2007	NORTHERN PIPE PRODUCTS 1309 39th Street NW Fargo, ND 58102	See notes below
4/1/2012	PIPELIFE JET STREAM, INC. P.O. Box 190 Siloam Springs, AR 72761	See notes below

**NOTE:**

1. Material must comply with requirement of description above and be rated above design pressure. Acceptable sizes are 4", 6", 8" and 12".
2. AWWA C900 water pipe for portable water shall be blue in color not be used for anything but potable water.
3. AWWA C900 water pipe for force mains shall be green in color.
4. AWWA C900 water pipe for reclaimed water shall be purple in color.