



**CITY OF SAN MARCOS
STANDARD PRODUCTS LIST**

SPL No. WW-308A

Sheet 1 of 1

for

**FACTORY RESTRAINED JOINT PVC WATER PIPE (4-INCH TO 12-INCH
DIAMETER)**

ISSUED: 09/01/2014

REVISED: 06/01/2018

DESCRIPTION: Pipe, polyvinyl chloride (PVC), 4" through 12" cast iron pipe size O.D. with elastomeric gasket joints and factory-installed internal joint restraint system for water service. Pipe must meet AWWA C900 DR14 Pressure Class 305. Joint restraint system must meet ASTM F 1674.

APPROVAL DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT
4/1/2011	JM EAGLE (formerly J-M Pipe & PW Eagle) 9 Peach Tree Hill Road Livingston, NJ 07039	Eagle Loc 900
4/1/2011	DIAMOND PLASTICS CORPORATION P.O. Box 2748 Lubbock, TX 79408-2748	Diamond Loc-21

NOTE:

1. Warning tape shall be placed on top of the pipe for the full length of restrained joint pipe. The warning tape shall be yellow and shall have black lettering at least 2 inches high that states "Restrained Joint / Junta de Restriccion" at intervals not exceeding 24 inches. The warning tape shall be polypropylene having a minimum thickness of 2 mils, a minimum width of 3 inches, and adhesive backing on the side opposite the lettering.
2. Material must comply with requirement of description above and be rated above design pressure. Acceptable sizes are 4", 6", 8" and 12".