



**CITY OF SAN MARCOS
STANDARD PRODUCTS LIST**

SPL No. WW-308C

Sheet 1 of 1

for

PVC WATER PIPE (16-INCH TO 24-INCH DIAMETER)

ISSUED: 09/01/2014

REVISED: 01/17/2023

DESCRIPTION: Pipe, polyvinyl chloride (PVC), 16"-24" nominal diameter w/ductile iron pipe size O.D. and Reiber- type steel-reinforced elastomeric gasket joints for water service, meeting current AWWA C905 or AWWA C900, Pressure Class 235 psi (DR18)

APPROVAL DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT
4/1/2013	WESTLAKE PIPE & FITTINGS (Formerly NAPCO) 2801 Post Oak Blvd. Suite 600 Houston, TX 77056	See notes below
4/1/2013	DIAMOND PLASTICS CORPORATION P.O. Box 1608 Grand Island, NE 68802-1608	See notes below
2/23/2016	JM EAGLE (formerly J-M Pipe & PW Eagle) 9 Peach Tree Hill Road Livingston, NJ 07039	See notes below
9/3/2020	PIPELIFE JET STREAM, INC. P.O. Box 190 Siloam Springs, AR 72761	See notes below

NOTE:

1. AWWA C905 or AWWA C900 water pipe shall not be used for wastewater force mains or to convey anything but potable water.
2. Markings shall include nominal size and OD basis (16" CI), PVC, Dimension Ratio (DR18), Pressure Class (PC 235), Test pressure for hydrotested pipe, AWWA C905 or AWWA C900 , manufacturer's name or trademark, production run record or lot code, mark of certifying agency.