



**VERTICAL VALVE (STANDARD)**

**HORIZONTAL VALVE**

**NOTE:**

1. LID MUST SAY "WATER" FOR A WATERLINE, "SEWER" FOR NONPOTABLE LINES OR "RECLAIM" FOR RECLAIMED WATER. REFER TO SPL WW 622.
2. IF DEPTH EXCEEDS 6', A SINGLE VALVE EXTENSION IS REQUIRED. VALVE EXTENSION CAN NOT BE STACKED.

REFERENCES  
DETAIL 1100S-1-SM

The City of San Marcos Engineering and Capital Improvements		CURRENT AS OF 1/1/2020	TYPICAL GATE VALVE 2" - 24"	
RECORD COPY SIGNED BY	2/15/2019	THE ARCHITECT/ENGINEER ASSUMES RESPONSIBILITY FOR APPROPRIATE USE OF THIS STANDARD.		STANDARD NO. <b>511S-7-SM</b>
Laurie Moyer, P.E.	ADOPTED			1 OF 1