



VERTICAL VALVE (STANDARD)

HORIZONTAL VALVE

NOTE:

1. LID MUST SAY "WATER" FOR A WATERLINE, "SEWER" FOR NONPOTABLE LINES OR "RECLAIM" FOR RECLAIMED WATER. REFER TO SPL WW 622.
2. IF DEPTH EXCEEDS 6', A SINGLE VALVE EXTENSION IS REQUIRED. VALVE EXTENSION CAN NOT BE STACKED.

REFERENCES
DETAIL 1100S-1-SM

| | | | |
|--|---------------------------------|--|---|
| <p>The City of San Marcos Engineering and Capital Improvements</p> | | <p>TYPICAL GATE VALVE 2" - 24"</p> | |
| <p>RECORD COPY SIGNED BY</p> <p>LAURIE MOYER, P.E.</p> | <p>2/15/2019</p> <p>ADOPTED</p> | <p>THE ARCHITECT/ENGINEER ASSUMES RESPONSIBILITY FOR APPROPRIATE USE OF THIS STANDARD.</p> | <p>STANDARD NO. 511S-7-SM 1 OF 1</p> |