



NOTES:

1. FOR SERVICE LINE 8" OR GREATER, SAMPLE TEE MUST BE 2" LARGER THAN SERVICE PIPE SIZE.
2. ALL CT ADAPTORS NEED TO BE CONCRETE ENCASED.
3. THERE WILL BE NO WASTEWATER CONNECTION BETWEEN THE GREASE TRAP AND WASTEWATER SAMPLE PORT.

The City of San Marcos Engineering and Capital Improvements		WASTEWATER SAMPLE PORT	
RECORD COPY SIGNED BY	6/2/2017	THE ARCHITECT/ENGINEER ASSUMES RESPONSIBILITY FOR APPROPRIATE USE OF THIS STANDARD.	STANDARD NO. 520S-4B-SM
LAURIE MOYER, P.E.	ADOPTED		1 OF 1