

**Item No. 111S
Excavation**

111S.1 Description

This item shall govern: (1) the excavation and proper utilization or satisfactory disposal of all excavated materials, of whatever character, within the limits of the Work and (2) construction, compaction, shaping and finishing of all designated earthwork areas in accordance with the specification requirements outlined herein and in conformity with the required lines, grades and typical cross sections indicated on the Drawings or as directed by the Engineer or designated representative. When not otherwise included in the Contract Documents, this item shall include the work described in Specification Item Nos. 101S, "Preparing Right of Way", No. 102S, "Clearing and Grubbing", No. 104S, "Removing Portland Cement Concrete", No. 132S "Embankment" and No. 201S, "Subgrade Preparation".

This specification is applicable for projects or work involving either inch-pound or SI units. Within the text inch-pound units are given preference followed by SI units shown within parentheses.

111S.2 Submittals

The submittal requirements of this specification item may include:

- A. A permit when utility adjustments are made in the right-of-way,
- B. A plan for removal and deposition of all 'Waste' materials, and
- C. A Blasting Permit if blasting is required and allowed on the project.

111S.3 Classification

All excavation shall be unclassified and shall include all materials encountered regardless of their nature or the manner in which they are removed.

111S.4 Construction Methods

Prior to commencement of this work, all required erosion control and tree protection measures shall be in place. The existing utilities shall be located and shall be protected as specified in the Standard Contracts Document Section 00700, "General Conditions" and/or indicated on the Drawings. A permit shall be required when utility adjustments are to be made in preparation for construction in the right-of-way, as specified in Section 5.2.0 of the City of Austin Utilities Criteria Manual.

Construction equipment shall not be operated nor construction materials stockpiled under the canopies of trees, unless otherwise indicated on the Drawings. Excavation or embankment materials shall not be placed within the drip line of trees until tree wells are constructed, that conform to Specification Item No. 610S, "Preservation of Trees and Other Vegetation".

All excavation shall be performed as specified herein and shall conform to the established alignment, grades and cross sections indicated on the Drawings. Suitable excavated

materials shall be utilized, insofar as practical, in constructing required embankments. The construction of all embankments shall conform to Specification Item No. 132S, "Embankment". No material shall be stockpiled within the banks of a waterway.

Unsuitable excavated materials or excavation in excess of that needed for construction shall be known as "Waste" and shall become the property of the Contractor. Unsuitable material encountered below the subgrade elevation in roadway cuts, when declared "Waste" by the Engineer or designated representative, shall be replaced with material from the roadway excavation or with other suitable material as approved by the Engineer. It shall become the Contractor's responsibility to dispose of this material off the limits of the right of way in an environmentally sound manner at a permitted disposal site.

All blasting shall conform to the Provisions of the Standard Contract Document Section 01550, "Public Safety and Convenience". In all cases, a Blasting Permit must be obtained in advance from the City of Austin, Department of Public Works and Transportation.

Adequate dewatering and drainage of excavation shall be maintained throughout the time required to complete the excavation work.

* See Modifications for additional information

111S.5 Measurement

All accepted excavation will be measured by either Method A or B as follows:

(1) Method A

Measurement of the volume of excavation in cubic yards (cubic meters: 1 square meter is equal to 1.306 square yards) by the average end area methods. Cross-sectional areas shall be computed from the existing ground surface to the established line of the subgrade, as shown on typical sections in the Drawings, over the limits of the right of way or other work limits, including parkway slopes and sidewalk areas.

(2) Method B

Measurement of the volume of excavation in cubic yards (cubic meters: 1 square meter is equal to 1.306 square yards), based upon the average end area method taken from pre-construction cross sections and planned grades. The planned quantities for excavation will be used as the measurement for payment for this item.

111S.6 Payment

This item will be paid for at the contract unit bid price for "Excavation", as provided under measurement Method A or B as included in the bid. The bid price shall include full compensation for all work herein specified including dewatering, drainage, subgrade preparation, unless otherwise indicated, and the furnishing of all materials, equipment, tools, labor and incidentals necessary to complete the work.

Payment will be made under one of the following:

Pay Item No. 111S-A: Excavation	Per Cubic Yard.
Pay Item No. 111S-B: Excavation, Plan Quantity	Per Cubic Yard.

End

<i>SPECIFIC</i> CROSS REFERENCE MATERIALS
Specification Item 111S, "EXCAVATION"

City of Austin Standard Contract Documents

<u>Designation</u>	<u>Description</u>
00700	General Conditions
01550	Public Safety and Convenience

City of Austin Utilities Criteria Manual

<u>Designation</u>	<u>Description</u>
Section 5.2.0	Permit for Excavation in the Public Right-of-Way

City of Austin Technical Specifications

<u>Designation</u>	<u>Description</u>
Item No. 101S	Preparing Right of Way
Item No. 102S	Clearing and Grubbing-
Item No. 104S	Removing Portland Cement Concrete
Item No. 132S	Embankment
Item No. 201S	Subgrade Preparation
Item No. 236S	Proof Rolling
Item No. 610S	Preservation of Trees and Other Vegetation

<i>RELATED</i> CROSS REFERENCE MATERIALS
Specification Item 111S, "EXCAVATION"

City of Austin Standard Contract Documents

<u>Designation</u>	<u>Description</u>
01500	Temporary Facilities

City of Austin Standard Specifications

<u>Designation</u>	<u>Description</u>
Item No. 120S	Channel Excavation
Item No. 203	Lime Treatment for Materials In Place
Item No. 204S	Portland Cement Treatment for Materials In Place
Item No. 230S	Rolling (Flat Wheel)
Item No. 232S	Rolling (Pneumatic Tire)
Item No. 234S	Rolling (Tamping)
Item No. 602S	Sodding for Erosion Control
Item No. 604S	Seeding for Erosion Control
Item No. 622S	Diversion Dike
Item No. 628S	Sediment Containment Dikes
Item No. 642S	Silt Fence

City of Austin Standard Details

<u>Designation</u>	<u>Description</u>
No. 610S-1	Tree Protection Fence Locations
No. 610S-2	Tree Protection Fence, Type B Chainlink
No. 610S-3	Tree Protection Fence, Type B Wood
No. 610S-4	Tree Protection Fence, Modified Type A

No. 610S-5	Tree Protection Fence, Modified Type B
No. 621S-1	Diversion
No. 622S-1	Diversion Dike
No. 624S-1	Earth Outlet Sediment Trap
No. 625S-1	Grade Stabilization Structure
No. 627S-1	Grass Lined Swale
No. 627S-2	Grass Lined Swale With Stone Center
No. 628S	Triangular Sediment Filter Dike

City of Austin Standard Details

<u>Designation</u>	<u>Description</u>
No. 628S-1	Hay Bale Dike
No. 629S-1	Brush Berm
No. 630S-1	Interceptor Dike
No. 631S-1	Interceptor Swale
No. 632S-1	Storm Inlet Sediment Trap
No. 633S-1	Landgrading
No. 634S-1	Level Spreader
No. 635S-1	Perimeter Dike
No. 636S-1	Perimeter Swale
No. 637S-1	Pipe Slope Drain (Flexible)
No. 637S-2	Pipe Slope Drain (Flexible)
No. 638S-1	Pipe Outlet Sediment Trap
No. 639S-1	Rock Berm
No. 641S-1	Stabilized Construction Entrance
No. 642S-1	Silt Fence
No. 643S-1	Stone Outlet Structure
No. 644S-1	Stone Outlet Sediment Trap

The Code of the City of Austin, Code of Ordinances, Volume 1

<u>Designation</u>	<u>Description</u>
Article 14-11-181	Permit Required
Article 14-11-189	Conditions for Permit Issuance
Article 14-11-190	Excavation Sequence and Permit Term

Texas Department of Transportation: Standard Specifications for Construction and Maintenance of Highways, Streets, and Bridges

<u>Designation</u>	<u>Description</u>
Item No. 100	Preparing Right of Way
Item No. 110	Excavation
Item No. 112	Subgrade Widening
Item No. 132	Embankment
Item No. 150	Blading
Item No. 158	Specialized Excavation Work
Item No. 160	Furnishing and Placing Topsoil
Item No. 164	Seeding for Erosion Control
Item No. 204	Sprinkling
Item No. 210	Rolling (Flat Wheel)
Item No. 211	Rolling (Tamping)
Item No. 213	Rolling (Pneumatic Tire)
Item No. 260	Lime Treatment for Materials Used as Subgrade (Road Mixed)
Item No. 265	Lime-Fly Ash (LFA) Treatment for Materials Used as Subgrade

Texas Department of Transportation: Manual of Testing Procedures

<u>Designation</u>	<u>Description</u>
Tex-103-E	Determination of Moisture Content of Soil Materials
Tex-104-E	Determination of Liquid Limit of Soils
Tex-105-E	Determination of Plastic Limit of Soils
Tex-106-E	Method of Calculating the Plasticity Index of Soils
Tex-114-E	Laboratory Compaction Characteristics and Moisture-Density Relationship of Subgrade & Embankment Soil
Tex-115-E	Field Method for Determination of In-Place Density of Soils and Base Materials