

**Item No. 130S  
Borrow**

**130S.1 Description**

This item shall govern required excavation, removal and proper utilization of materials secured from sources, selected by the Contractor and approved by the Engineer or designated representative. The compaction of embankments constructed from borrow as provided herein shall conform to the appropriate sections of Specification Item Nos. 132S, "Embankment" and 236S, "Proof Rolling".

Borrow will be used only when indicated on the Drawings or directed by the Engineer or designated representative and shall only be acquired from approved sources.

This specification is applicable for projects or work involving either inch-pound or SI units. Within the text inch-pound units are given preference followed by SI units shown within parentheses.

**130S.2 Submittals**

The submittal requirements of this specification item may include:

- A. Identification of Class, source and characteristics (P.I., linear shrinkage, etc.) of proposed borrow material, and
- B. A plan for managing and maintaining borrow sites.

**130S.3 Materials**

All authorized borrow shall conform to one of the following classes:

**Class A (Select Borrow)**

Class A Borrow material shall consist of suitable granular material, free from vegetation or other objectionable matter and reasonably free from lumps of earth. When tested by standard TxDOT laboratory methods Tex-105-E, Tex-106-E and Tex-107-E, the Class A Select Borrow, shall meet the following requirements:

The Liquid Limit shall not exceed	45
The Plasticity Index shall not exceed	15
The bar linear shrinkage shall not be less than	2

**Class B (Borrow)**

Class B Borrow material shall consist of suitable non swelling [i.e. soils with a plasticity index (P.I.) less than 20] earth material such as loam, clay or other such materials that will form a stable embankment.

**Class C (Topsoil)**

See Standard Specification Item No. 601S.3(A)

### 130S.4 Construction Methods

Prior to commencing this work, all required erosion control and environmental measures shall be in place. All suitable materials removed from excavations shall be used, insofar as practicable in the formation of embankments conforming to Specification Item No. 132S, "Embankment", as otherwise indicated on the Drawings or as directed by the Engineer or designated representative. The completed work shall conform to the established alignment, grades and cross section as shown on the Drawings. The additional material necessary to complete the work described above shall be "Borrow" of the class specified.

The Contractor shall arrange for borrow from one of the following sources:

1. Existing borrow pit,
2. New borrow pit, or
3. Surplus excavated material from a site, with a site development permit.

The Contractor shall notify the Engineer 3 weeks prior to opening a pit or any other borrow source to allow necessary testing for approval of materials. All borrow sites shall comply with the requirements of the site development permit.

During construction, borrow sources shall be kept drained to permit final cross sections to be measured, when required.

Borrow sites shall be managed and maintained to minimize the impact of the appearance of the natural topographic features and at no time create a potential hazard to the public.

### 130S.5 Measurement

Borrow will be measured by the cubic yard (cubic meters: 1 cubic meter is equal to 1.196 cubic yards) in its final position based upon the average end areas, calculated from pre-construction cross sections and plan grades. The plan quantities for Borrow or Topsoil will be used as the measurement for payment for this item.

### 130S.6 Payment

All work performed as required herein and measured as provided under "Measurement" will be paid for at the unit bid price. The bid prices shall include full compensation for furnishing all labor; all materials; all royalty and freight involved; all hauling and delivering on the road; and all tools, equipment and incidentals necessary to complete the work. Payment will not be made for unauthorized work.

Payment will be made under one of the following:

<b>Pay Item No. 130S-A:</b> Class A (Select Borrow), Plan Quantity	Per Cubic Yard.
<b>Pay Item No. 130S-B:</b> Class B (Borrow), Plan Quantity	Per Cubic Yard.
<b>Pay Item No. 130S-T:</b> Class C (Topsoil), Plan Quantity	Per Cubic Yard.

End

<b><u>SPECIFIC</u> CROSS REFERENCE MATERIALS</b>
Specification 130S, "BORROW"

City of Austin Standard Specifications

<u>Designation</u>	<u>Description</u>
Item No. 132S	Embankment
Item No. 236S	Rolling (Proof)

Texas Department of Transportation: Manual of Testing Procedures

<u>Designation</u>	<u>Description</u>
Tex-105-E	Determination of Plastic Limit of Soils
Tex-106-E	Method of Calculating the Plasticity Index of Soils
Tex-107-E	Determination of Bar Linear Shrinkage of Soils

<b><u>RELATED</u> CROSS REFERENCE MATERIALS</b>
Specification 130S, "BORROW"

City of Austin Standard Contract Documents

<u>Designation</u>	<u>Description</u>
00700	General Conditions

City of Austin Standard Specifications

<u>Designation</u>	<u>Description</u>
Item No. 101S	Preparing Right of Way
Item No. 102S	Clearing and Grubbing
Item No. 110S	Street Excavation
Item No. 111S	Excavation
Item No. 230S	Rolling (Flat Wheel)
Item No. 232S	Rolling (Pneumatic Tire)
Item No. 234S	Rolling (Tamping)
Item No. 602S	Sodding for Erosion Control
Item No. 604S	Seeding for Erosion Control
Item No. 610S	Preservation of Trees and Other Vegetation
Item No. 622S	Diversion Dike
Item No. 628S	Sediment Containment Dikes
Item No. 642S	Silt Fence

City of Austin Standard Details

<u>Designation</u>	<u>Description</u>
No. 610S-1	Tree Protection Fence Locations
No. 610S-2	Tree Protection Fence, Type B Chainlink
No. 610S-3	Tree Protection Fence, Type B Wood
No. 610S-4	Tree Protection Fence, Modified Type A
No. 610S-5	Tree Protection Fence, Modified Type B
No. 621S-1	Diversion
No. 622S-1	Diversion Dike
No. 624S-1	Earth Outlet Sediment Trap
No. 625S-1	Grade Stabilization Structure
No. 626S-1	Grass Lined Swale
No. 627S-1	Grass Lined Swale With Stone Center
No. 628S	Triangular Sediment Filter Dike

No. 628S-1	Hay Bale Dike
No. 629S-1	Brush Berm
No. 630S-1	Interceptor Dike
No. 631S-1	Interceptor Swale
No. 632S-1	Storm Inlet Sediment Trap
No. 633S-1	Landgrading
No. 634S-1	Level Spreader

City of Austin Standard Details

<u>Designation</u>	<u>Description</u>
No. 635S-1	Perimeter Dike
No. 636S-1	Perimeter Swale
No. 637S-1	Pipe Slope Drain (Flexible)
No. 637S-2	Pipe Slope Drain (Flexible)
No. 638S-1	Pipe Outlet Sediment Trap
No. 639S-1	Rock Berm
No. 641S-1	Stabilized Construction Entrance
No. 642S-1	Silt Fence
No. 643S-1	Stone Outlet Structure
No. 644S-1	Stone Outlet Sediment Trap

Texas Department of Transportation: Standard Specifications for Construction and Maintenance of Highways, Streets, and Bridges

<u>Designation</u>	<u>Description</u>
Item No. 100	Preparing Right of Way
Item No. 110	Excavation
Item No. 132	Embankment
Item No. 158	Specialized Excavation Work
Item No. 160	Furnishing and Placing Topsoil
Item No. 164	Seeding for Erosion Control
Item No. 204	Sprinkling
Item No. 210	Rolling (Flat Wheel)
Item No. 211	Rolling (Tamping)
Item No. 213	Rolling (Pneumatic Tire)

Texas Department of Transportation: Manual of Testing Procedures

<u>Designation</u>	<u>Description</u>
Tex-103-E	Determination of Moisture Content of Soil Materials
Tex-104-E	Determination of Liquid Limit of Soils
Tex-114-E	Laboratory Compaction Characteristics and Moisture-Density Relationship of Subgrade & Embankment Soil
Tex-115-E	Field Method for Determination of In-Place Density of Soils and Base Materials