

Item No. 610S
Preservation of Trees and Other Vegetation

610S.1 Description and Definitions * See Modifications for additional information

This item shall govern the proper care, protection and treatment of trees and other vegetation in the vicinity of the permitted development activity (as defined in Land Development Code ~~25-1-21(27)~~). All work shall be performed in accordance with the City approved drawings and specifications (e.g. Standard Series 600) or as approved by the City Arborist (as defined below). Tree pruning and/or treatments shall be performed under the direct supervision of a qualified arborist (as defined below) or as allowed by the City Arborist.

Definitions

City Arborist – ~~City official designated by the Director of the Planning and Development Review Department (Land Development Code 25-8-603) or as designated by the City Arborist.~~

Oak wilt - a tree disease caused by a fungus “Ceratocystis fagacearum” that infects the vascular system of Oak “genus Quercus” trees and prevents water transport through the trunk and canopy of the tree. This usually fatal tree disease can be spread by certain insects that come into contact with tree wounds or by interconnected tree roots. February through June is a high risk period due to the stage of the fungus and insect activity. See section 610S.4(H) for additional requirements for preventing Oak wilt infection.

Qualified Arborist – ~~an individual engaged in the profession of arboriculture or closely related field who, through experience, education, and related training, possesses the competence to provide for, or supervise, the management of trees and other woody plants (as defined in the most current version of ANSI A300 (Part 1)-2001, section 4.1).~~

This specification is applicable for projects or work involving either inch-pound or SI units. Within the text and accompanying tables, the inch-pound units are given preference followed by SI units shown within parentheses.

610S.2 Submittals

The following is a list of the minimum submittal requirements for this specification item shall include:

- A. Identification of the location, type of protective fencing (i.e. A, ~~B or C~~), materials of construction and installation details;
- B. Qualified Arborist credentials (i.e. proof of certification from the International Society of Arboriculture, licenses, resume and/or references);
- C. Type, location and construction details for proposed tree wells;

- D. Location, type, materials of construction and installation details for permeable paving;
- E. Proposed nutrient mix specifications and when required by the City Arborist, soil and/or foliar analysis for fertilizer applications.

* See Modifications for additional information on new sections

610S.3 Materials

- A. Protective Fencing and Signage * See Modifications for additional information

~~Protective fencing is designated as the materials used to protect the root zones of trees as illustrated in City of Austin Standard Detail 610S-1. Three basic types of protective fencing materials are allowed by the City of Austin. Type A and Type B are typical applications and shall be installed where damage potential to a tree root system is high, while Type C shall be installed where damage potential is minimal. The specific type of protective fencing for the work shall be as indicated on the drawings. Type C fence materials shall be subject to approval by the City Arborist. Type C fencing shall be replaced by Type A or Type B fencing as directed by the City Arborist if it fails to perform the necessary function.~~

- 1. ~~Type A Chain Link fence (Typical Application high potential damage)~~

~~Type A protective fencing shall be installed in accordance with City of Austin Standard Details 610S-2 and 610S-4 and shall consist of a minimum five-foot (1.5 meters) high chain link fencing with tubular steel support poles or "T" posts.~~

- 2. ~~Type B Wood Fence (Typical Application high potential damage)~~

~~Type B protective fencing shall be installed in accordance with City of Austin Standard Details 610S-3 and 610S-5 and shall consist of any vertical planking attached to 2x4-inch (50 x 100 mm) horizontal stringers which are supported by 2x4-inch (50 x 100 mm) intermediate vertical supports and a 4x4-inch (100 x 100 mm) at every fourth vertical support.~~

- 3. ~~Type C Other Materials (Limited Application minimal potential damage)~~

~~The following materials may be permitted as alternates for limited or temporary applications (3 days or less) where tree damage potential is minimal (as determined by the City Arborist):~~

- ~~(a) High visibility plastic construction fencing.~~

~~The fabric shall be 4 feet (1.2 meters) in width and made of high density polyethylene resin, extruded and stretched to provide a highly visible international orange, non-fading fence. The fabric shall remain flexible from 60oF to 200oF (-16oC to 93oC) and shall be inert to most chemicals and acid. The fabric pattern may vary from diamond to circular with a minimum unit weight of 0.4 lbs./Ft. (0.6 kilograms per meter).~~

~~The fabric shall have a 4 foot (1.2 meters) width minimum tensile yield strength (Horizontal) of 2000 psi [13.9 megaPascals], ultimate tensile~~

~~strength of 2680 psi [18.5 megaPascals] (Horizontal) and a maximum opening no greater than 2 inches (50 mm).~~

- (b) Other approved equivalent restraining material.

The fencing materials, identified in (a) and (b) above, shall be supported by steel pipe, tee posts, U posts or 2" x 4" (50 mm x 100 mm) timber posts that are a minimum of 5-1/2 feet (1.68 meters) in height and spaced no more than 8 feet (2.44 meters) on centers. The fabric shall be secured to post by bands or wire ties.

4. Signage * See Modifications for additional information

~~A laminated sign, no smaller than 8.5 X 11 inches, shall be posted on each tree protective device, and at least every 100 linear feet on protective fencing, identifying the following information: Tree & Root Protection Zone, Per City of Austin code (Chapter 25-8, Subchapter B, Article 1) this protective device is to remain in place for the entirety of the development project and illegal removal is subject to fines and work suspensions. Additional information can be obtained at the City Arborist (512-974-1876) web site (<http://www.ci.austin.tx.us/trees>). Zona de Protección del Árbol y las Raíces: el dispositivo protector debe quedarse en el lugar para la totalidad del proyecto de la construcción. Para información adicional, contacta la Arborista Municipal (512) 974-1876 o http://www.ci.austin.tx.us/trees/trees_spanish.htm.~~

B. Trunk Protection (Limited Application)

When indicated on the drawings or directed by the City Arborist tree trunk protection shall be provided in accordance with City of Austin Standard Details 610S-4 and 610S-5. Tree trunk protection shall consist of any 2 x 4-inch (50 x 100 mm) or 2 x 6-inch (50 x 150 mm) planking or plastic strapping and shall be attached in a manner that does not damage the tree.

C. Tree Dressing * See Modifications for additional information

~~Wound treatments should not be used to cover wounds or pruning cuts, except when recommended for disease (see section 610S.4 (H)), insect, mistletoe, or sprout control (from ANSI A300 (Part 1) 2001, section 5.4.1).~~

D. Tree Wells for Raised Grades

When existing grades are raised by more than 4 inches (10.16 cm), the tree root system shall be protected by the installation of tree wells in accordance with City of Austin Standard Detail 610S-6. Native stone or non-toxic timber shall be used for the separator wall of the well and PVC conforming to ASTM D-2729, SDR-35 shall be used for the aeration systems in fill areas.

E. ~~Permeable Paving (Environmental Criteria Manual Section 3.5.A.1)~~

~~Permeable segmented pavers in conjunction with PVC pipe aeration system or concrete on gravel base with cored holes shall be used to protect existing tree root zones when indicated on the drawings or directed by the City Arborist.~~

F. Fertilizer

Humate/nutrient solutions with mycorrhizae components or soil injection at recommended rates are to be used when appropriate. Construction which will be completed in less than 90 days may use materials at half the recommended rates. Alternative organic fertilizer materials are acceptable when approved by the City Arborist.

* See Modifications for additional information on new sections

610S.4 Construction Methods

A. Protective Fencing

All trees and shrubs in the proximity of the construction site shall be carefully checked for damage prior to initiation of the permitted development activity.

All individual or groups of trees, shrubs, and natural areas shown to be protected on the drawings or identified to be protected by the City Arborist, shall be protected during construction with temporary fencing as indicated on the drawings or as directed by the City Arborist.

Protective fences (section 610S.4.A) shall be installed prior to the start of any site preparation work (clearing, grubbing, or grading), and shall be maintained in functioning condition throughout all phases of the construction project.

Protective fence locations in close proximity to intersecting streets or drives shall adhere to the sight distance (Section 1.3.1.C.6) and desirable sight triangle (Figure 1-6 criteria found in the City of Austin Transportation Criteria Manual).

1. Protective fences shall be constructed at the locations (typically the outer limits of the critical root zone) and with materials indicated on the drawings to prevent the following (Environment Criteria Manual, Appendix P-2, Note 6):
 - (a) Soil compaction in the root zone area resulting from vehicular traffic or storage of equipment or materials.
 - (b) Critical root zone disturbances due to grade changes [greater than 4" (10.16 cm) cut or fill] or trenching not reviewed and authorized by the City Arborist.
 - (c) Damage to exposed roots, trunks or limbs by mechanical equipment.
 - (d) Other activities detrimental to trees such as chemical storage, concrete truck cleaning, and fires.
2. Exceptions to the installation of protective fences at the tree drip lines may be permitted in the following cases:
 - (a) Where there is to be an approved grade change, impermeable paving surface, tree well, or other such site development, the fence shall be erected no more than 2 feet (0.6 meters) beyond the area of disturbance unless approved by the City Arborist;
 - (b) When permeable paving is to be installed within a tree's critical root zone, the fence shall be erected at the outer limits of the permeable paving area (prior to any site grading so that this enclosed area is graded separately to minimize root damage);

* See Modifications
for additional
information

- (c) When trees are located close to a proposed building or other construction activity (Environment Criteria Manual, Appendix P-2, Note 6.c), the fence shall be erected up to 10 feet (3 meters) to allow work space between the fence and the structure. ~~Apply organic mulch to a depth of 8 inches [30.48 cm] in the unprotected root zone area;~~
- (d) When there are street-side pedestrian walkways, fences shall be constructed in a manner that does not obstruct safe passage;
- (e) When there are severe space constraints due to tract size or other special requirements, the Contractor shall contact the City Arborist to discuss alternatives.

When any of the exceptions listed above will result in a fence being located closer than five (5) feet (1.5 meters) to a tree trunk, the Contractor shall also protect the trunk with strapped-on planking to a height of 8 feet [2.4 meters] (or to the limits of lower branching) in addition to the fencing requirement (City of Austin Standard Details 610S-4 and 610S-5).

B. Pruning and Repair of Damage

Tree pruning, to provide clearance for the work and/or to remove hazards, shall be performed under the direct supervision of a qualified arborist and shall follow standards identified in ANSI A300 (Part 1), "Pruning". A minimum clearance height of eight (8) feet (2.4 meters) above the street level must be provided and maintained for all existing trees if adjacent to a sidewalk. However, if the limbs of trees overhang the curb line or edge of travel lane of any street, a minimum clearance height of fourteen (14) feet (4.2 meters) is required (Transportation Criteria manual section 6.2.3,A, 4, "Clearance Height"). Pruning shall provide the minimum clearance needed to perform the work or remove a hazard unless otherwise directed by the City Arborist to comply with transportation criteria or to mitigate for damage.

If tree damage compromises a tree's structural integrity then the area shall be adequately secured until a qualified arborist makes an assessment of the tree and corrective actions are completed with approval from the City Arborist. Damage to oak trees shall be treated immediately, with consideration for site safety, to reduce the risk of Oak Wilt infection (See 610S.4.H, "Oak Wilt Prevention"). Tree root wounds shall be treated to remove loose, damaged tissue from in and around the wound or if necessary the root shall be cut cleanly and covered with topsoil, or other material approved by the City Arborist, to prevent drying of root tissue and to create a favorable environment for root sprouting. Trunk wounds shall also be treated to remove loose, damaged tissue around the wound. Tree canopy repairs shall be performed in accordance with the most current version of ANSI A300 (Part 1), "Pruning", to prevent further damage to the tree and to promote recovery of the tree to sound condition. The ANSI standard describes proper pruning methods for limb removal and for making finish pruning cuts.

~~Trees damaged or removed without prior approval or where minimum design criteria is exceeded due to failure to maintain approved tree protection shall be mitigated (Environmental Criteria Manual section 3.5.4, "Mitigation Measures") in accordance with Land Development Code Chapter 25-8, Subchapter B, Article 1.~~

* See Modifications for additional information

All trees damaged during construction shall receive an application of fertilizer within the drip line conforming to Standard Specification Item No. 606S, "Fertilizer" at the rate of 4 pounds per caliper inch (.07 kilograms per caliper mm).

* See modifications for more information

C. Cutting and Filling Around Trees

When the depth of an excavation or embankment exceeds 4 inches (10.16 cm) within the critical root zone of any tree with a trunk diameter greater than 8 inches (200 mm), the City Arborist may require a tree well to be constructed per the City of Austin approved specifications and details (Section 610S.3.D and City of Austin Standard Detail 610S-6).

D. ~~Paving Around Trees~~

~~Where new paving within the ½ critical root zone of any tree greater than a 8 inches (10.16 cm) diameter is approved, a permeable pavement and aeration system may be required by the City Arborist per the City of Austin Standard Detail (Section 610S.3.E, Environmental Criteria Manual Section 3.5.3.A.1 and Figure 3-8) must be installed as indicated on the Drawings, except for street construction.~~

E. Tree Removal * See modifications for more information

~~Tree removal shall comply with Land Development Code Chapter 25-8, Subchapter B, Article 1. An approved permit, or an approved site plan is required for removal of trees 8" and larger (see Environmental Criteria manual section 3.3.2.A.2 and figure 3-1 for measurement standards) with additional requirements for City Parkland properties and for Hill Country Roadway Corridor sites. Trees 19 inches in diameter and greater are defined as protected trees and require specific review from the City Arborist to approve a permit or site plan for removal. In addition heritage trees require a more extensive evaluation by the City Arborist and may require rulings from boards and commissions.~~

All trees to be removed shall be performed in a manner that does not damage the canopies, trunks or root systems of remaining trees and that protects all existing facilities, improvements and vegetation. Removal of oak trees shall follow the Oak Wilt Prevention procedures per the City of Austin Standards (Section 610S.4,(H)). All tree material shall be removed from the site unless authorized by the City Arborist or if it will be used as wood chips or mulch.

When a tree or shrub is scheduled for removal, it shall be cut to a maximum depth of 12 inches (30.5 cm) below the surrounding grade (the tree(s) should be removed at grade, and with hand saws, in situations where other tree root systems are present which are to be preserved). When applicable, after tree removal, soil shall be placed in the hole to a depth matching the existing grade.

All damage resulting from tree removal or pruning shall be repaired at the Contractor's own expense and shall follow guidelines in this specification.

F. Final Cleanup

All temporary tree and shrub preservation and protection measures shall be removed when the construction has been completed and any mulch applications shall be removed or reduced to no more than 3 inches (7.62 cm) depth.

G. Root Zone Aeration and Fertilization

As a component of an effective remedial tree care program per Environmental Criteria Manual section 3.5.4, preserved trees within the limits of construction may require soil aeration and supplemental nutrients. Soil and/or foliar analysis should be used to determine the need for supplemental nutrients. The City Arborist may require these analyses as part of a comprehensive tree care plan. Soil pH shall be considered when determining the fertilization composition as soil pH influences the tree's ability to uptake nutrients from the soil. If analyses indicate the need for supplemental nutrients, then humate/nutrient solutions with mycorrhizae components are highly recommended. In addition, soil analysis may be needed to determine if organic material or beneficial microorganisms are needed to improve soil health. Materials and methods are to be approved by the City Arborist (512-974-1876) prior to application. The owner or general contractor shall select a fertilization contractor and ensure coordination with the City Arborist.

Pre-construction treatment should be applied in the appropriate season; ideally the season preceding the proposed construction. Minimally, areas to be treated include the entire critical root zone of trees as depicted on the City approved plans. ~~Treatment should include, but not limited to, fertilization, soil treatment, mulching, and proper pruning.~~ * See modifications for more information

Post-construction treatment should occur during final revegetation or as determined by a qualified arborist after construction. Construction activities often result in a reduction in soil macro and micro pores and an increase in soil bulk density. To ameliorate the degraded soil conditions, aeration via water and/or air injected into the soil is needed or by other methods as approved by the City Arborist. The proposed nutrient mix specifications and soil and/or foliar analysis results need to be provided to and approved by the City Arborist prior to application (Fax # 512-974-3010). Construction which will be completed in less than 90 days may use materials at ½ recommended rates. Alternative organic fertilizer materials are acceptable when approved by the City Arborist. Within 7 days after fertilization is performed, the contractor shall provide documentation of the work performed to the City Arborist, Planning and Development Review Department. P.O. Box 1088, Austin, TX 78767. This note should be referenced as item #1 in the Sequence of Construction.* See modifications for more information

H. Oak Wilt Prevention Policy

1. Purpose and Scope

The purpose of this Oak Wilt Prevention Policy is to identify measures that city staff and city-hired contractors and their sub-contractors, who perform the services of removing or trimming trees, will take to prevent the spread of oak wilt.

2. Definitions

Oak Wilt Disease: A tree disease caused by the fungus, *Ceratocystis fagacearum*. The fungus infects the vascular system of a tree. The vascular system contains vessels which transport moisture throughout the tree. The vessels of an infected tree effectively become blocked by the infection of the fungus, and cannot transport adequate moisture to sustain a healthy or living tree. In most cases, the end result is tree mortality.

3 Prevention Policy

- (a) Prior to beginning field work, all city staff associated with projects involving potential contact with oak trees shall be made aware of the city's official Oak Wilt Policy by receiving and reading a written copy of this policy. Staff receiving a written copy of the policy shall include, but not limited to, project managers, equipment operators responsible for removing or trimming trees, or operators using heavy equipment which could cause wounding of susceptible oaks in the use of the equipment. In addition, individual city departments will provide a written copy of the Oak Wilt Policy to contractors participating in city projects in areas where oak trees are present before initiating field work.
- (b) When possible, city staff and contractors should avoid trimming, pruning, or wounding Live Oaks and Red Oaks (Spanish, Shumard, Texas Red, and Blackjack oaks) from February through June.
- (c) At all times and irrespective of limb size, all cuts and wounds to oak trees shall be dressed immediately using a non-phytotoxic tree wound dressing. Stump cuts and damaged roots (both above and below ground) shall also be dressed. * See modifications for more information
- (d) Disinfection of pruning tools, saws, and related equipment is mandatory during the trimming or pruning of oak trees. Disinfection of tree removal and trimming equipment shall occur before work begins in a project area, between work in individual oak trees, and again prior to leaving a project area. Acceptable disinfectants include either aerosol disinfectant or a 10 percent bleach-water solution.

*NOTE: Although this policy would require the disinfection of pruning equipment before and between oak trees as a precaution, research does not substantiate disinfection as a means of preventing the transmission of the oak wilt disease.

4. Disposal Policy

- (a) Chipping or shredding the wood from infected trees to use as mulch is an acceptable means of recycling the wood. Chipping or shredding allows the wood to dry out quickly, thereby killing the fungus.
- (b) Burning diseased wood is an acceptable means of disposal. Burning diseased logs will kill the fungus, and the fungus will not spread with the smoke. * See modifications for more information
- (c) Logs from diseased Red Oaks, that are not chipped, shredded, or burned shall be disposed of at a landfill.* See modifications for more information
- (d) Firewood from diseased Red Oak trees shall not be stored near healthy trees where fungal spores or insects that carry the spores have the potential to spread the fungus to healthy trees. It is recommended to store oak firewood under a sheet of clear plastic, tightly sealing the edges of plastic with soil or bricks. Doing so will prevent any spore carrying beetles from escaping and will solarize and heat the stored firewood to speed the drying process. It is also recommended to use

clear plastic, as black plastic will reveal any escape holes to the beetles.

- (e) In situations where diseased Red Oak trees are identified and are not accessible for chipping, shredding, or removal, the trunk of the diseased tree should be girdled, and the stem treated with an appropriate herbicide to deaden the tree and hasten the desiccation and drying of the wood below the minimum moisture content that could support the development of fungal spores.

610S.5 Measurement * See modifications for more information

~~Tree and shrub pruning, fencing, drains, fertilization, etc. will not be measured for payment unless included as a contract pay item.~~ Tree wells for tree protection will be measured by the units, complete in place, conforming to the Drawings and City of Austin Standard Detail 610S-6, "Tree Protection, Tree Wells".

Removal of existing trees will be measured per each tree.

610S.6 Payment

The work and materials prescribed herein with the exception of the Protective Fencing and Tree Well (Tree Protection) will not be paid for directly but shall be included in the unit price bid for the item of construction in which this activity is used, unless a payment item is included as a contract pay item.

Payment will be made under:

| | | |
|------------------------------------|---|----------------------------|
| Pay Item 610S-A: | Protective Fencing Type A Chain Link fence (Typical Application-high damage potential) | Per Lineal Foot |
| Pay Item 610S-B: | Protective Fencing Type B Wood Fence (Typical Application-high damage potential) | Per Lineal Foot |
| Pay Item 610S-C: | Protective Fencing Type C Other Materials (Limited Application-minimal damage potential) | Per Lineal Foot |
| Pay Item 610S-D: | Tree Well (Tree Protection) | Per Each |
| Pay Item 610S-E: | Tree Trunk Protection, Wood Planking | Per Each |
| Pay Item 610S-R: | Removal of Existing Trees | Per Each |

End

| |
|---|
| SPECIFIC CROSS REFERENCE MATERIALS |
| Specification Item 610S, "Preservation of Trees and Other Vegetation" |

City of Austin Standard Specification Items

| <u>Designation</u> | <u>Description</u> |
|--------------------|--------------------|
| Item No. 606S | Fertilizer |

City of Austin Standard Details

| <u>Designation</u> | <u>Description</u> |
|----------------------------|---|
| Item No. 610S-1 | Tree Protection Fence Locations |
| Item No. 610S-2 | Tree Protection Fence, Type A, Chainlink |
| Item No. 610S-3 | Tree Protection Fence, Type B, Wood |
| Item No. 610S-4 | Tree Protection Fence, Modified Type A, Chainlink |
| Item No. 610S-5 | Tree Protection Fence, Modified Type B, Wood |
| Item No. 610S-6 | Tree Protection, Tree Wells |

City of Austin Transportation Criteria Manual

| <u>Designation</u> | <u>Description</u> |
|--------------------|--------------------------|
| Section 1.3.1.C.6 | Sight Distance |
| Section 6.2.3.A.4 | Clearance Height |
| Figure 1-6 | Desirable Sight Triangle |

City of Austin Environmental Criteria Manual

| <u>Designation</u> | <u>Description</u> |
|-----------------------|---|
| Appendix P-2, Note 6 | Exceptions to Installing Fences |
| Appendix P-2, Note 6c | Trees close to proposed buildings----- |
| Appendix P-6 | Remedial Tree Care Notes |
| Section 3.3.2.A.2 | Diameter of trees----- |
| Section 3.5.0 | Design Criteria |
| Section 3.5.3.A.1 | Permeable Paving |
| Figure 3-8 | Example of Minimum Design Criteria Applied to Permeable Parking |

City of Austin Land Development Code

| <u>Designation</u> | <u>Description</u> |
|--------------------|--------------------------------|
| Section 25-8-603 | Tree Protection Administration |
| Section 25-8-623 | Inspection by City Arborist |

ASTM, American Society for Testing and Materials

| <u>Designation</u> | <u>Description</u> |
|--------------------|--|
| D-2729 | Specification for Poly (Vinyl Chloride) (PVC) Sewer Pipe and Fittings |

RELATED CROSS REFERENCE MATERIALS

Specification 610S, "Preservation of Trees and Other Vegetation"

City of Austin Standard Specification Items

| <u>Designation</u> | <u>Description</u> |
|--------------------|------------------------|
| Item No. 101S | Preparing Right of Way |
| Item No. 102S | Clearing and Grubbing |
| Item No. 111S | Excavation |
| Item No. 120S | Channel Excavation |
| Item No. 132S | Embankment |
| Item No. 608S | Planting |

**Texas Department of Transportation: Standard Specifications for
Construction and Maintenance of Highways, Streets, and Bridges**

| <u>Designation</u> | <u>Description</u> |
|--------------------|--------------------------------|
| Item No. 100 | Preparing Right of Way |
| Item No. 110 | Excavation |
| Item No. 132 | Embankment |
| Item No. 158 | Specialized Excavation Work |
| Item No. 160 | Furnishing and Placing Topsoil |
| Item No. 166 | Fertilizer |
| Item No. 168 | Vegetative Watering |