



2 INCH TAP OR LARGER

NOTES

1. GATE VALVE AND CORPORATION STOP CONNECTED NEXT TO MAIN WILL BE TURNED TO THE OFF POSITION.
2. REMOVE 12" OF SERVICE LINE AFTER THE GATE VALVE OR CORPORATION STOP AND DISCARD AS DIRECTED IN PLANS OR PER ENGINEERS INSTRUCTION.
3. AFTER THE GATE VALVE OR CORPORATION STOP INSTALL AN APPROVED PLUG.
4. IF GATE VALVE OR CORPORATION STOP SHOWS ANY SIGNS OF LEAKING REMOVE ALL FITTINGS FROM MAIN (SLEEVE/SADDLE AND VALVE). SEAL THE TAP AREA ON THE MAIN WITH A SLEEVE CLAMP CENTERED WHERE THE ORIGINAL TAP WAS MADE.

The City of San Marcos
Engineering and Capital Improvements

CURRENT AS OF
1/1/2021

ABANDON TAP

RECORDED COPY SIGNED BY
LAURIE MOYER, P.E.

9/11/2014
ADOPTED

THE ARCHITECT/ENGINEER ASSUMES
RESPONSIBILITY FOR APPROPRIATE
USE OF THIS STANDARD

520S-AT-SM
N.T.S. STANDARD DETAIL